

PRICE BID  
NOTICE INVITING QUOTATION No: 09  
Dated:09/06/2025

SI No	DESCRIPTION OF WORK	UNIT	QUANTITY	RATE	AMOUNT
1	<p>Disinfection of overhead / underground water storage tanks of Hostels, Administrative Building and all Departments of Cotton University, a) Stage 1. Mechanical Dewatering: This process involve cleaning off dirt, mud, algae from the walls, manhole &amp; surrounding and pumping out water, removal of semi sludge with the help of submersible &amp; sludge pump..</p> <p>b) Stage 2. Removal of Sludge: In this stage all the sludge which has settled on the floor of the tank shall be sucked out using sludge pumping equipments and mud, sand &amp; solid particles shall be removed from the tank with the help of sludge pump.</p> <p>c) Stage 3. High pressure cleaning: Cleaning the walls &amp; ceiling of the tanks using high pressure water jet machine which can create water pressure more than 100 bars. d) Stage 4. Vacuum Cleaning: The remaining sludge shall be removed with the help of Industrial Vacuum Cleaner. e) Stage 5. Application of anti bacterial spray: In the Fifth very important stage, the walls &amp; ceiling shall be treated by spraying non toxic bio –degradable eco friendly antibacterial agent. f) Stage 6. UV Radiation: In the final Stage, Final sterilization and disinfection shall be done using UV Radiation by the UV Radiator to kill any suspended or floating bacteria remaining in the tank.</p>				
	MCB ,BKK Building	LITER	36000		
	Library	LITER	4000		
	CSIT	LITER	6000		
	Zoology	LITER	13000		
	Physics Dept.	LITER	6000		

*Sam*

*[Signature]*

*[Signature]*



Chemistry	LITER	20800		
New Arts Building	LITER	39000		
Botany	LITER	70200		
Adminstrative Building	LITER	4000		
Hospital	LITER	4000		
SKL Girls Hostel	LITER	38475		
NBD Girls Hostel	LITER	48000		
DKR Girls Hostel	LITER	18000		
MNDP Boys Hostel	LITER	33500		
SNBC Boys Hostel	LITER	17428		
RKB Boys Hostel	LITER	49500		
SRB Boys Hostel	LITER	70000		
		<b>Total</b>		

Date & Seal

Signature of the Bidder

*Daun*

*[Signature]*

*[Signature]*